

RSP Ruck Sanitärprodukte GmbH | Kirchstraße 1 | 83126 Flintsbach am Inn | Germany

RSP Ruck Sanitärprodukte GmbH  
Kirchstraße 1  
83126 Flintsbach am Inn  
Germany  
Phone: +49 (0) 80 34 / 70 82-0  
Fax: +49 (0) 80 34 / 70 82-22  
info@rsp-rohre.de  
www.rsp-rohre.de

## To our customers

**Geschäftsführer**  
Robert Ruck  
Amtsgericht Traunstein HRB 15744  
USt-IdNr.: DE813975261  
Steuer-Nr.: 156/136/80583

**Bankverbindung**  
Sparkasse Rosenheim-Bad Aibling  
BLZ 711 500 00  
Konto-Nr. 59972  
BIC/SWIFT: BYLADEM1ROS  
IBAN: DE53 7115 0000 0000 0599 72

## Declaration of Performance in accordance with annexe III Regulation (EU) No 305/2011

**No.: KML005**

- 1.) Unique identification code of the product type:  
**KML pipe system made of cast iron according to EN877**
- 2.) Identification of building product:  
**RSP-KML pipes and fittings made of cast iron (see product name)**
- 3.) Intended use of the construction:  
**Drainage of buildings especially for aggressive waste water**
- 4.) Name and contact address:  
**RSP Ruck Sanitärprodukte GmbH  
Kirchstraße 1  
D-83126 Flintsbach**
- 5.) Where applicable, authorised representative  
**Not applicable**
- 6.) System of assessment:  
**Reaction to fire of the pipe system (System 3), all other properties (System 4)**
- 7.) Details:  
**The approval of reaction to fire as per system 3 was carried out by the notified agency MFPA Leipzig, NB-Nr. 0800 and a classification report was released.**
- 8.) Product with a European Technical Assessment:  
**Not applicable**

9.) Declared performance:

<b>Essential characteristics</b>	<b>EN 877: 2010-01</b>	<b>Performance</b>
Reaction to fire	4.1.3 Reaction to fire, 5.7.3 External coatings and annex H – product group - cast iron - product group system	class A1 class A2-s1,d0
Internal pressure strength	4.7.5 Water tightness	pass
Dimension tolerances	4.2.2 External diameter 4.2.3 Wall thickness 4.2.5 Ovality	pass pass pass
Impact resistance	4.5.2 Mechanical properties	pass
Tightness Air and Water	4.7.5 Water tightness 4.7.6 Air tightness	pass pass
Durability aspects 1. Pipes 2. Fittings	4.6.3 External coatings	1. Zinc, Epoxy - pass 2. Epoxy - pass
Durability aspects 1. Pipes 2. Fittings	4.6.2 Internal coatings	1. Epoxy - pass 2. Epoxy - pass Resistant to salty spray ≥ 1500 h

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point number 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer



Flintsbach, 04.04.2019

Robert Ruck (Manager)